



CCD-420

Date: 05.11.17
To: Gregg Johnson
Company: Mortenson Construction
Project: 16246.000
Re: Minnesota Multi-Purpose Stadium

From: Kevin A. Taylor, AIA

All items contained herein are an integral part of the Construction Documents and shall be built accordingly.

Summary: ASI-420 – Video Rack Room Cooling Revision

Mechanical Sheets:

- M2.0704 – CRAC units added in Video Rack Room
- M2.0705 – FCUs added in Video Control and Production rooms.
- M3.0704 – Enlarged plan of Video Rack Room
- M4.06 – Controls sequence for CRAC units added.
- MEP0.03 – Fan Schedule updated.
- MEP0.04 – FCU Schedule updated.
- MEP0.06 – CRAC unit schedule updated.
- MP2.0704 – Chilled water extended to CRAC units.
- MP2.0705 – Chilled water extended to FCU units.
- MP2.0804 – Chilled water tapped in main.

Electronic Sheets:

- E1.B004 – Panel schedules updated for equipment.
- E1.B103 – Panel schedules updated for equipment.
- E2.0714 – Circuiting to CRAC units, transfer fans, and FCUs.

Attachments: CCD-420

In accordance with the terms of the Contract Documents and with approval of the owner as required:

1. [] Price above item(s) and submit a proposal with itemized cost breakdown for Owner's approval prior to proceeding with any work.

2. [X] PROCEED immediately to avoid or minimize delays in the work with the above items. Submit an itemized cost breakdown of labor and materials showing either credit or extra for Owner's review.



06-16-2014

HKS Inc.

Date

Minnesota Sports Facility Authority

Date

Distribution: John Hutchings (HKS), Scott Stenman (Hammes), Jim Cima (Vikings), Brent Leiter (Mortenson), Chad Scheckel (HKS), Dan Trafford (HKS), Jay Caddell(HKS)