

MINNESOTA MULTI-PURPOSE STADIUM
MINNEAPOLIS, MINNESOTA

SECTION 230902

LIFE SAFETY SYSTEMS

PART 1 - GENERAL

1.1 SCOPE

- A. The Section 23 09 00 contractor shall provide and install the system described in this section.
- B. Smoke exhaust for the areas identified in the Life Safety report.
- C. Stair pressurization.
- D. Combination Fire/Smoke Detector Control.
- E. Duct Mounted Smoke Detector Control.

1.2 APPLICABLE CODES AND STANDARDS

- A. NFPA 92A
- B. NFPA 92B
- C. NFPA 72
- D. IBC
- E. Minnesota State Building Code
- F. Life Safety Report by Code Consultant
- G. National Electric Code
- H. UL 555 & 5555
- I. UL 864/UUKL

1.3 RELATED SECTIONS

- A. Section 23 34 00 – Fans
Section 23 33 00 – Ductwork Accessories
Section 23 09 00 – Building Automation and Automatic Temperature Control Systems.
Section 28 ___ ___ – Addressable Fire Alarm System

PART 2 - PRODUCTS (Not Used)

MINNESOTA MULTI-PURPOSE STADIUM
MINNEAPOLIS, MINNESOTA

PART 3 - EXECUTION (Not Used)

END OF SECTION